

NOTICE
REQUEST FOR PROPOSALS
FOR 2019 OVERLAY FRYING PAN-ADDENDUM #1
EAGLE COUNTY, COLORADO

February 12, 2019

Potential Bidders on

RE: Addendum to the Request bids for the Eagle County 2019 Overlay Project

To Potential Bidders:

Eagle County has received a few questions regarding the Request for Bids for the Eagle County 2019 Overlay Project.

1. Can you clarify testing needed in item #8 in Exhibit B?

Materials testing and sampling for gradation, AC content and density shall be performed at 400 ton intervals.

2. Is there a bid bond required and if so what is the percentage?

Bid security shall be made payable to Owner in an amount of five percent (5%) of the bidder's maximum bid price, and in the form of a certified or bank check, or a bid bond issued by a surety meeting the requirements of paragraph 12 of the General Conditions.

If you have any additional questions please feel free to contact me.

Sincerely,

Eagle County Road & Bridge Department



John Harris
Road & Bridge Director

Work Phone: 970-328-3542

Email: john.harris@eaglecounty.us